WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

4 WELLS

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95358
Permit No.
Basin 212

NOTICE OF INTENT NO. 27588

1. OWNER Mike Beasley
MAILING ADDRESS 9524 W. Camelback Rd.
Phoenix AZ

ADDRESS AT WELL LOCATION
2475 S. Rancho Dr.
Las Vegas NV.

2. LOCATION SW ¼ SW ¼ Sec. 4 T. 21 N/S R. 61 E. Clark County

PERMIT NO. ____ Issued by Water Resources | 162-04-401-005 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Gravel		0.0	5.0	5
Brown Sand & Gravel		5.0	7.5	2.5
Lt Brown Sand w/Gravel		7.5	10.5	3.0
Silty Sand		10.5	12.5	2.0
Weakly Cemented		12.5	15.0	2.5
Tan Silty Sand w/Gravel		15.0	18.0	3.0
Tan Clayey Sand		18.0	25.0	7.0

DCNR/DWR
RECEIVED
MAR 16 2005
LAS VEGAS OFFICE

Date started 03/01, 2005
Date complated 03/03, 2005

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 25.0 Feet Depth Cased 25.0 Feet

HOLE DIAMETER (BIT SIZE)

		From	To	
11½	Inches	0.0 Feet	25.0 Feet	2EA
11½	Inches	0.0 Feet	24.0 Feet	2EA
	Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.25		SCH 40 PVC	0.0	25.0
4.25		SCH 40 PVC	0.0	24.0

Perforations:
Type perforation Machine Slot
Size perforation .020
From 25.0 feet to 10.0 feet
From 24.0 feet to 9.0 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 1'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 25, 24 feet to 8, 7 feet

9. WATER LEVEL
Static water level 13 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Eagle Drilling Services, LLC
Contractor
Address 7150 Placid St
Contractor
Las Vegas NV. 89119

Nevada contractor's license number issued by the State Contractor's Board 51266

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2272

Signed [signature]
By driller performing actual drilling on site or contractor

Date 03/03/05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627