WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

4 WELLS

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95360
Permit No.
Basin 212

NOTICE OF INTENT NO. 27583

1. OWNER Mike Beasley
MAILING ADDRESS 9524 W. Camelback Rd.
Phoenix AZ

ADDRESS AT WELL LOCATION 2475 S. Rancho Dr.
Las Vegas NV.

2. LOCATION SW ¼ SW ¼ Sec. 4 T. 21 N/S R. 61 E. Clark County
PERMIT NO. Issued by Water Resources
Parcel No. 162-04-411-005
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Gravel		0.0	5.0	5
Brown Sand & Gravel		5.0	7.5	2.5
Lt Brown Sand w/Gravel		7.5	10.5	3.0
Silty Sand		10.5	12.5	2.0
Wenny Cementation		12.5	15.0	2.5
Tan Silty Sand w/Gravel		15.0	18.0	3.0
Tan Clayey Sand		18.0	25.0	7.0

DCNR/DWR
RECEIVED
MAR 16 2005
LAS VEGAS OFFICE

Date started 03/01, 2005
Date completed 03/03, 2005

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 25.0 Feet Depth Cased 25.0 Feet

HOLE DIAMETER (BIT SIZE)

		From		To		
11½	Inches	0.0	Feet	25.0	Feet	2EA
11½	Inches	0.0	Feet	24.0	Feet	2EA
	Inches		Feet		Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.25		Sch 40 PVC	0.0	25.0
4.25		Sch 40 PVC	0.0	24.0

Perforations:
Type perforation Machine Slot
Size perforation .020
From 25.0 feet to 10.0 feet
From 24.0 feet to 9.0 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 1'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 25, 24 feet to 8, 7 feet

9. WATER LEVEL
Static water level 13 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eagle Drilling Services, LLC (Contractor)
Address 7150 Placid St (Contractor)
Las Vegas NV. 89119
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2272
Signed (By driller performing actual drilling on site or contractor)
Date 03/03/05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627