

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 05370
 Permit No. _____
 Basin 71
 NOTICE OF INTENT NO. 43685

1. OWNER GONZALEZ ILO E FANSO ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS PO Box 3741 7100 TORREY LN
Winnemucca NV 89446 WNNMCA, NV 89445
 2. LOCATION S.W. 1/4 NW 1/4 Sec. 18 T. 35 N/S R. 38 E Humboldt County
 PERMIT NO. 010-611-12 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Blow SAND		0	6	6
SAND GRAVEL		6	22	16
Cobbles		22	26	4
SAND/Gravel/Cobbles		26	80	54
Boulders		80	82	2
Gravelly Clay		82	94	12
SAND/Gravel/10% clay		94	102	8
SAND/Gravel/6% clay		102		
INTER BEDDED Clay			204	102
Cobbles		204	218	14

8. WELL CONSTRUCTION
 Depth Drilled 218 Feet Depth Cased 217 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 218 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>10</u>	<u>188</u>	<u>+1</u>	<u>217</u>

Perforations:
 Type perforation Factory + Trench cut
 Size perforation 5/32 x 6
 From 195 feet to 217 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 47 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 47 feet to 218 feet

9. WATER LEVEL
 Static water level 118' feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature cool °F Quality good

Date started June 29 2004
 Date completed July 2 2004

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>12.8</u>		<u>5</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fred Anderson + Son Drilling Contractor
 Address 10760 Grass Valley Rd Contractor
Winn NV
 Nevada contractor's license number issued by the State Contractor's Board 021467
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 01375
 Signed [Signature]
 Date July 6, 2004

RECEIVED
 ON AUG 25 AM 10:38
 STATE ENGINEERS OFFICE