WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95371
Permit No.
Basin 71

NOTICE OF INTENT NO. 44417

1. OWNER Jerry Lynch
MAILING ADDRESS 4210 Brayton Rd.
Winnemucca NV 89445

ADDRESS AT WELL LOCATION 4210 Brayton Road
Winnemucca NV 89445
Lot #20

2. LOCATION NE ¼ SW ¼ Sec. 7 T. 35 N/S R. 38 E. Humboldt County
PERMIT NO. Issued by Water Resources
Parcel No. 010-483-04
Subdivision Name Sonoma Ranchio

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Topsoil | | 0 | 3 | 3 |
| Sand Fine Gravel | | 3 | 60 | 57 |
| 3/4 Gravel | | 60 | 80 | 20 |
| Boulders + Clay | | 80 | 200 | 120 |
| Sand + Clay | 10 | 200 | 215 | 15 |
| Boulders + Clay | | 215 | 230 | 15 |
| wet Clay + Sand | 20 | 230 | 260 | 30 |

RECEIVED 04 JUL 20 AM 11:08 STATE ENGINEER'S OFFICE

Date started June 23 2004
Date completed June 25 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 27 | | 4 |

RECEIVED 04 AUG 25 AM 10:38 STATE ENGINEER'S OFFICE

8. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 5/8 Inches | | 0 Feet | 260 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 10 | 188 | +1 | 260 |

Perforations:
Type perforation Factory
Size perforation 3/32 x 4
From 230 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 260 feet

9. WATER LEVEL
Static water level 135' feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling, Inc Contractor
Address 10760 Grass Valley Rd Contractor
Winnemucca NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed By driller performing actual drilling on site or contractor
Date June 26, 2004

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627