

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
 WELL DRILLER'S REPORT

OFFICE USE ONLY  
 Log No. 95383  
 Permit No. \_\_\_\_\_  
 Basin 101

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 54554

1. OWNER **CHRH**  
 MAILING ADDRESS P.O. Box 5010  
Fallon, Nv. 89407  
 ADDRESS AT WELL LOCATION 4363 Rancheria Rd.  
Fallon, Nv. 89406

2. LOCATION SE 1/4 NW 1/4 Sec 16 T 19 N R 28 E **Churchill County**  
 PERMIT NO. 008-122-24 AL 8-9-04  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	15	15
clay		15	35	20
sand and clay		35	40	5
sand		40	44	4
clay		44	60	16
clay and sand		60	62	2
black sand and clay		62	80	18
black clay		80	81	1
black sand		81	84	3
sand and clay		84	100	16
black sand		100	115	15
sand		115	140	25
black clay and sand		140	165	25
black clay		165	180	15
sand		180	195	15
clay		195	200	5
sand	XX	200	205	5

8. WELL CONSTRUCTION  
 Depth Drilled 205 Feet Depth Cascd 205 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 205 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6PVC	3.82	.258	20	205

Perforations:  
 Type perforation saw cut  
 Size perforation 1/8  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50 ft.  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 150 feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ 35 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality unknown

Date started April 13, 20 04  
 Date completed April 14, 20 04

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Parsons Drilling, Inc.  
 (CONTRACTOR)

7. WELL TEST DATE

TEST METHOD:	Bailer	Pump	Air Lift
	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
G.P.M.	Draw Down (Feet Below Static)		Time (Hours)
<u>50</u>			<u>1 hr</u>

Address P.O. Box 1265  
Fallon, Nv. 89407  
 Nevada contractor's license number issued by the State Contractor's Board 29064  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1454  
 Signed Norman Parsons  
 By driller performing actual drilling on site or contractor  
 Date 4-2-04

RECEIVED  
 04 JUL 26 PM 12:10  
 STATE ENGINEERS OFFICE