WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95384
Permit No.
Basin 85

NOTICE OF INTENT NO. 47965

1. OWNER Washoe County Dept of Water
MAILING ADDRESS Resources. 4930 Energy Way Reno Nv 775-954-4654

ADDRESS AT WELL LOCATION Sky Ranch Park #1 8900 La Posada Sparks Nv (Spanish Springs Valley)

2. LOCATION SW ¼ SW ¼ Sec. 35 T 21 N/S R 20 E Washoe County
PERMIT NO. M10 1325 Issued by Water Resources | 53409101 Parcel No. | Sky Ranch Park Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Tan fine Sandy Desert loam		0	2½	2½
Changes to Tan very fine Sandy Clay balls @ 2½				
Tan Clayey Sand (Not moist)		2½	4	1½
Tan Clay - Some Organics		4	8	4
Tan medium #18 Sand		8	9½	1½
Some jasper + Quartz Chips				
Gray, Pea gravelly CAS Sand		9½	10	½
Tan, medium Very Sandy Clay		10	11	1
Tan, Tight fine Sandy Clay		11	12	1
Fine, Tan sandy Clay		12	16	4
Tan Fine sandy Clay, moist @ 16'		16	22	6
Tan very fine Sandy Silty Clay		22	25	3
Brown, Very hard dry Clay		25	37	12
Contact Water Table	39.6			
Tan Silty fine Sandy Clay		37	45	8

Date started 6-1-04, 19
Date completed 6-1-04, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 45 Feet Depth Cased 45 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6.625 Inches		0 Feet	45 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	Sch. 40 PVC		0	45

Perforations:
Type perforation 0.020" Slot
Size perforation
From 40 feet to 45 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0 To 32'
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 36 feet to 45 feet

9. WATER LEVEL
Static water level 36.40 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name R.N. Pennington Contractor
Address 333 W Nye Ln Contractor
Carson City Nv 89706
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller FP-1857
Signed R.N. Pennington
By driller performing actual drilling on site or contractor
Date 6-3-04

(Rev. 3-93) USE ADDITIONAL SHEETS IF NECESSARY (O)-627