

OFFICE USE ONLY  
 Log No. 953916  
 Permit No. \_\_\_\_\_  
 Basin 93

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49269

1. OWNER William & Nenita Mosegaard ADDRESS AT WELL LOCATION ALUM ROCK RD  
 MAILING ADDRESS 7900 N Virginia St. spc 21 RENO NV  
RENO NV 89506

2. LOCATION NW 1/4 SW 1/4 Sec. 11 T. 22 N/S R. 19 E. WASHOE County  
 PERMIT NO. 079-500-37 RED ROCK ESTATES & ANTELOPE VALLEY  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Light Brown		0	20	20
Dark Brown		20	155	135
Light Gray / soft	155	155	173	18
Dark Gray / hard		173	197	24
Light Brown / soft		197	224	27
Dark Brown / soft		224	230	6
Dark Gray / soft		230	232	2
Dark Gray / hard		232	242	10
Light Brown / soft		242	245	3
Dark Gray / soft & hard		245	265	20
Light Brown / soft		265	278	13
Dark Gray / soft		278	280	2

8. WELL CONSTRUCTION  
 Depth Drilled 280 Feet Depth Cased 280 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 280 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	STEEL	.188	0	20
6 5/8	PVC	SDR 21 F480	20	280

Perforations:  
 Type perforation Factory Screen  
 Size perforation 4X.125  
 From 215 feet to 280 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100 feet  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 280 feet

9. WATER LEVEL  
 Static water level 153 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name William George Mosegaard  
Contractor

Address 7900 N Virginia St. spc 21  
Contractor  
RENO NV 89506

Nevada contractor's license number issued by the State Contractor's Board 53579  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2211  
 Signed William George Mosegaard  
By driller performing actual drilling on site or contractor  
 Date 8-11-2004

Date started september 20, 2003  
 Date completed August 11, 2004

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
	<u>20+</u>	<u>5</u>	<u>2</u>