COPIES TO
- DIVISION OF WATER RESOURCES
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95400
Permit No.
Basin 101

NOTICE OF INTENT NO. 52888

1. OWNER Bob Hammon
MAILING ADDRESS 5075 Alcorn Road
Fallon, NV 8406 27

ADDRESS AT WELL LOCATION Bob Hammon
482 River Village Drive
Fallon, NV 89406

2. LOCATION ~~NW~~ ¼ ~~SE~~ ¼ Sec ~~29~~ T 19 N R 28 E Churchill County
PERMIT NO. SE VE (Issued by Water Resources) 008-421-46 (Parcel No.) R 1-24-05 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	4	4
Brown CLay		4	7	3
Brown Sand/Gray		7	30	23
Brown Clay		30	34	4
Brown CLay		34	39	5
Black Sand		39	47	8
Blac/Gray Clay		47	55	8
Black Sand		55	68	13
Black Clay		68	74	6
Brown Gravel		74	85	9
Brown CLay		85	94	9
Gray Clay		94	98	4
Black Clay		98	105	7
Gray Clay		105	130	25
Black Sand		130	145	15
Gray Clay		145	163	18
Brown Clay		163	168	5
Brown CLay	XX	168	176	8

RECEIVED 04 JUN 16 AM 10:28 STATE ENGINEERS OFFICE

Date started 05/26, 20 04
Date completed 05/26, 20 04

7. WELL TEST DATE
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 176 Feet Depth Cased 176 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	176 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6 pVC	3.82	.258	20	176

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 171 feet to 176 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100 ☐ Neat Cement
Placement Method: ☒ Pumped ☒ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 176 feet

9. WATER LEVEL
Static water level 21 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling Inc (CONTRACTOR)
Address P.O. Box 1265 (CONTRACTOR)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1454
Signed Norman Parsons
By driller performing actual drilling on site or contractor
Date 06/11/04

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com