WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65406
Permit No.
Basin 045

NOTICE OF INTENT NO. 34265

1. OWNER Roger Jones
MAILING ADDRESS 270 512th Elko NV 89803

ADDRESS AT WELL LOCATION North side of Lamillioc Hwy. Pleaten Valley

2. LOCATION SW 1/4 SE 1/4 Sec. 23 T 33 N/S R 57 E Elko County
PERMIT NO. 65595 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED: ☐ New Well ☒ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE: ☐ Domestic ☒ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE: ☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay		0	5	5
Boulders		5	20	15
Clay		20	25	5
Oxidize Granite Rock	X	25	80	55
Sandy Limestone		80	90	10
Oxidize Granite Rock	X	90	120	30
Sandy limestone	X	120	150	30
Oxidize Granite Rock		150	200	50
Sandy Clay		200	215	15
Oxidize Granite Rock	X	215	250	35
Sandy limestone	X	250	305	55

RECEIVED 04 AUG 30 PM 12:19 STATE ENGINEER'S OFFICE

Date started 7-20-04, 19__
Date completed 7-29-04, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx	200		57

8. WELL CONSTRUCTION
Depth Drilled 305 Feet Depth Cased 305 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 1/4	Inches	0	Feet	305	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	16.94	.188	+2	305

Perforations:
Type perforation Mill slots
Size perforation 3/16 x 3"
From 145 feet to 185 feet
From 205 feet to 305 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 305 feet

9. WATER LEVEL
Static water level 84 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fertig Drilling Co (Contractor)
Address PO Box 525 (Contractor)
Elko NV 89803
Nevada contractor's license number issued by the State Contractor's Board 0021904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 8-26-04

USE ADDITIONAL SHEETS IF NECESSARY