WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95407
Permit No.
Basin 103

NOTICE OF INTENT NO. 49568

1. OWNER R&B Developement
MAILING ADDRESS 1380 Greg St.
Sparks, NV 89431

ADDRESS AT WELL LOCATION At the corner of Rye Grass & Daffodil in the River Park subdivision outside of Dayton, NV.

2. LOCATION SW 1/4 NE 1/4 Sec. 33 T 17N N/S R 22E E Lyon County
PERMIT NO. Issued by Water Resources — Parcel No. — River Park / Former Rolling A Ranch Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Removed 200' of 10", turbine pump. Measured static water level at 25'. Measured depth of well at 471'. Bailed debris from well to a depth of 497', where we hit hard bottom and could not retreive any debris. Installed 16" Mills Knife and perforated 6 rows per foot from 115' to surface. Installed 483' of 2" tremme line. The following day we pumped in 34 cubic yards of neat cement from the bottom of the well to surface. Well volume should have only required approx 27 cubic yards. Casing was cut off approximately 3' below ground level.				

RECEIVED 04 AUG 31 AM 10:14 WATER RESOURCES OFFICE

Date started 08/25/2004, 19__
Date completed 08/26/2004, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased 500' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16		.250	+1	500'

Perforations:
Type perforation Mills Knife from surface to 115'
Size perforation 1/4 x 1' from 116 to 500'
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 500
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From surface feet to 500' feet

9. WATER LEVEL
Static water level 25' feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Carson Pump (Contractor)
Address P.O. Box 20159 (Contractor)
Carson City, NV. 89721
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed Don Trompe (By driller performing actual drilling on-site or contractor)
Date 08/30/2004

USE ADDITIONAL SHEETS IF NECESSARY