WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95416
Permit No.
Basin 102

NOTICE OF INTENT NO. 57664

1. OWNER Jason Stewart
MAILING ADDRESS
ADDRESS AT WELL LOCATION 3785 E. 8th St. Silver Springs, Nv.

2. LOCATION SE ¼ SE ¼ Sec. 16 T. 17 N/S R. 25 E. Lyon County
PERMIT NO. Issued by Water Resources | Parcel No. 17-364-13 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☑ Other Bud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand | | 0 | 6 | |
| Gray clay | | 6 | 23 | |
| Sand | | 23 | 68 | |
| Tan clay | | 68 | 121 | |
| Sand Gravel | | 121 | 143 | |
| Gray clay | | 143 | 163 | |
| Gravel | ✓ | 163 | 191 | |
| Gravel Clay mix | ✓ | 191 | 220 | |

RECEIVED 04 SEP 14 AM 10:57 STATE ENGINEERS OFFICE

Date started 8-11, 2004
Date completed 8-12, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| Produced about | | 50 | 6pm |

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches From 0 Feet To 220 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 1300 | 3/16 | +1 | 20 |
| 6 5/8 | 300 | SDR 21 | 20 | 220 |

Perforations:
Type perforation Scill Saw
Size perforation 16
From 160 feet to 180 feet
From 217 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 220 feet

9. WATER LEVEL
Static water level 53 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc Contractor
Address PO Box 599 Contractor
Silver Springs NV. 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1877
Signed [signature] By driller performing actual drilling on site or contractor
Date 8-12-04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627