

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 95430  
 Permit No. \_\_\_\_\_  
 Basin 73

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 53349

1. OWNER NEVADA DEPT OF AGRICULTURE ADDRESS AT WELL LOCATION EAST SIDE MERIDIAN ROAD 0.3 MILES NORTH OF DEBBY X-SECTION  
 MAILING ADDRESS 350 CAPITAL HILL AVENUE  
RENO NV 89502

2. LOCATION SW 1/4 SW 1/4 Sec. 2 T. 25 N/S R. 31 E. PERSHING County  
 PERMIT NO. MO-1332 07-451-09 Subdivision Name \_\_\_\_\_  
Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
GRAY-BROWN SILT + VERY FINE SAND		0	3.5	3.5
GRAY DRY CLAY + SILT		3.5	4	0.5
DARK GRAY CLAY		4	9	5.0
DARK GRAY MOIST CLAY BECOMING LIGHTER GRAY NEAR 14'		9	14	5.0
LIGHT GRAY CLAY	✓	14	19	5.0
LIGHT GRAY CLAY + SILT	✓	19	26	7.0

04 SEP -2 AM 10:46  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 26 Feet Depth Cased 26 Feet

HOLE DIAMETER (BIT SIZE)  
 From 6.625 Inches To 26 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>		<u>SCHED 40</u>	<u>0</u>	<u>26</u>

Perforations:  
 Type perforation MACHINE SLOT  
 Size perforation .01"  
 From 16 feet to 26 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 12  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 12 feet to 26 feet

9. WATER LEVEL  
 Static water level 17.65 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality \_\_\_\_\_

Date started August 16 2004  
 Date completed August 16 2004

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>0.8</u>		<u>1.0</u>


10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name \_\_\_\_\_ Contractor  
 Address \_\_\_\_\_ Contractor

Nevada contractor's license number issued by the State Contractor's Board CP-2178  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller RP-2178

Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 9/2/04

# WILDHORSE PASS QUAD



3930  
23  
3924AT  
3926T  
3927AT  
3927  
3928T  
3924T  
1-54  
1-187  
28  
27  
26  
3924T  
3922AT  
3922T  
3918AT  
WESTERGARD ROAD  
BM 3917  
ROAD  
3922T  
3920  
3920  
3922T  
CORRALS  
33  
34  
35  
T 26 N  
3913AT  
3914T  
T 25 N  
PETERSON ROAD  
BM 3915  
SOMMERS  
DITCH 3917AT  
Grain Bins  
3911  
3915T  
1-186  
CORRAL  
WELL  
Levee  
BIG  
FIVE  
Levee  
3911T  
3920  
3916T  
ARMY DRAIN ROAD  
BM 3907  
DERBY ROAD  
3911  
3919T  
3908  
RIVER