


COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES



OFFICE USE ONLY

Log No. 95437

Permit No. \_\_\_\_\_

Basin 103

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49468

PRINT OR TYPE ONLY

1. OWNER KARL & KRISTA WATTS  
 MAILING ADDRESS 506 PEBBLE DAYTON, NV 89403  
 ADDRESS AT WELL LOCATION 335 JAMES AVE. DAYTON, NV 89403

2. LOCATION NW 1/4 SW 1/4 Sec 5 T 16 N R 22 E LYON County  
 PERMIT NO. NA 19-652-05 SUTRO COUNTRY LAND LOT 49

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<b>BROWN SAND,SILT</b>		<b>0</b>	<b>60</b>	
<b>SAND,SMALL GRAVEL</b>		<b>60</b>	<b>90</b>	
<b>SANDY BROWN CLAY</b>		<b>90</b>	<b>120</b>	
<b>SANDY BROWN CLAY+ SMALL GRAVEL</b>		<b>120</b>	<b>130</b>	
<b>SANDS &amp; GRAVEL</b>		<b>130</b>	<b>160</b>	
<b>BROWN CLAYS &amp; SILT</b>		<b>160</b>	<b>220</b>	
<b>SAND, SMALL GRAVEL</b>		<b>220</b>	<b>250</b>	
<b>BROWN CLAY &amp; SILT</b>		<b>250</b>	<b>260</b>	

8. WELL CONSTRUCTION  
 Depth Drilled 260 Feet Depth Cased 260 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Feet 260 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6"</u>		<u>.188</u>	<u>+2</u>	<u>220'</u>

Perforations:  
 Type perforation MILL SLOT  
 Size perforation 3/32"  
 From 220 feet to 260 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 260 feet to 50 feet

9. WATER LEVEL  
 Static water level 48 feet below land surface  
 Artesian flow NO G.P.M. 30 P.S.I.  
 Water temperature COLD °F Quality NA

Date started 11/14, 20 03  
 Date completed 11/18, 20 03

7. WELL TEST DATE

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>30</u>	<u>220</u>	<u>2HRS</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name NEVADA PUMP & DRILLING  
 (CONTRACTOR)  
 Address PO BOX 2227  
 (CONTRACTOR)  
DAYTON, NEVADA 89403

Nevada contractor's license number issued by the State Contractor's Board 46357

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790

Signed Marty Lopez  
 By driller performing actual drilling on site or contractor

Date 12/15/03

RECEIVED  
 04 OCT - 4 PM 2:11  
 STATE ENGINEERS OFFICE