COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95439
Permit No.
Basin 103

NOTICE OF INTENT NO. 53523

1. OWNER CORNERSTONE CONSTRUCTION
MAILING ADDRESS 1273 FIGUERO WY
CARSON CITY, NV 89701

ADDRESS AT WELL LOCATION 9805 PACIFIC VIEW DR
STAGECOACH, NV 89429

2. LOCATION SW ¼ SW ¼ Sec 10 T 17 N R 23 E LYON County

PERMIT NO. (Issued by Water Resources) 15-402-20 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BLOW SANDS		0	3	3
HARDPAN CLAY		3	9	6
DG SANDS		9	63	54
BROWN CLAY		63	91	28
BROWN SILTY SANDS		91	135	44
COURSE DG GRAVELS	XXX	135	180	45

RECEIVED 04 OCT -1 AM 11:13 STATE ENGINEER'S OFFICE

Date started 9/10, 20 04
Date completed 9/11, 20 04

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+	30	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	180 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8sdr21	4.06	.216	20	180

Perforations:
Type perforation SAW CUT
Size perforation 3X3/32
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 55 ☐ Neat Cement
Placement Method: ☐ Pumped ☒ Cement Grout
☒ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 55 feet to 180 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M 25+ P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed [signature] By driller performing actual drilling on site or contractor
Date 9/28/04