


REPORT NO. **A04.080**

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**



LOG NO. 95447  
PERMIT NO. \_\_\_\_\_  
BASIN 85  
NOTICE OF INTENT NO. 52131

1. OWNER Elic Stafford ADDRESS OF WELL 445 Santiago Ct.  
MAILING ADDRESS 905 Lyman Ave. Reno, NV 89509 Sparks, NV 89436  
2. WELL LOCATION NW 1/4 NW 1/4 SEC. 31 T 21 R 21 E Washoe COUNTY  
PERMIT NO. \_\_\_\_\_ PARCEL NO. 076-390-31 SUBDIVISION NAME \_\_\_\_\_

3. TYPE OF WORK

New Well  Replace  Recondition  
 Deepen  Plug  Other

4. PROPOSED USE

Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE

Cable  Rotary  RVC  
 Air  Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Dirt & Rock		0	6	6
Volcanic Rock		6	12	6
Sand, Clay & Volcanic Rock		12	25	13
Heavy Clay, Sand & Volcanic Rock		25	55	30
Clay & Sand		55	70	15
Clay, Sand & D.G.		70	170	100
Black Rock & Clay		170	185	15
Multi Color Volcanic Rock & Clay		185	255	70
Hard Volcanic Rock		255		
& Gravels Multi Sized	X	255	268	13

RECEIVED  
OCT 12 PM 12:31  
STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION

Depth Drilled **268** Depth Cased **268**

HOLE DIAMETER (BIT SIZE)

**10 5/8** Inches **0** Feet **50** Feet  
**8 1/2** Inches **50** Feet **268** Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
<b>6 5/8</b>	<b>12.92</b>	<b>.188</b>	<b>+2</b>	<b>268</b>

PERFORATIONS:

Type Perforation **FAC SAW** Size Perforation **3/32 X 3**  
From **248** Feet to **268** Feet  
From \_\_\_\_\_ Feet to \_\_\_\_\_ Feet  
From \_\_\_\_\_ Feet to \_\_\_\_\_ Feet

SURFACE SEAL:  Yes  No SEAL TYPE:

Seal Depth **50**  Neat Cement  
 Cement Grout

PLACEMENT METHOD:  Pumped  Concrete Grout

Poured  Bentonite

GRAVEL PACKED:  Yes  No

From **50** Feet to **268** Feet

9. WATER LEVEL

Static Water Level **178** Feet Below Land Surface  
Artesian Flow \_\_\_\_\_ GPM \_\_\_\_\_ PSI  
Water Temperature **Cool** F Quality **Clear**

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Aqua Drilling & Well Service, Inc.**

Address **675 Edison Way  
Reno, NV 89502**

DRILLER'S LIC. NO. \_\_\_\_\_  
NV. CONTRACTOR'S LIC. NO. **15291** ON SITE **1981**

Signed *Richard*  
By driller performing actual drilling on site or contractor

Dated **September 22, 2004**

Date Started **9/21/04** Date Completed **9/22/04**

7. WELL TEST DATA

TEST METHOD  Bailer  Pump  Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	<b>20+</b>		<b>50 Min.</b>

Notes : UTM:  
**0270369**  
**4392356** Elevation: **4638'**