

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
 WELL DRILLER'S REPORT



OFFICE USE ONLY

Log No. 95459  
 Permit No. \_\_\_\_\_  
 Basin 163

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 53525

1. OWNER NORTH EAST CONSTRUCTION ADDRESS AT WELL LOCATION 145 BRANTINGHAM CT  
 MAILING ADDRESS 30 HILLTOP DRIVE DAYTON, NV 89403  
CARSON CITY, NV 89706

2. LOCATION SE 1/4 NW 1/4 Sec 9 T 16 N R 22 E LYON County  
 PERMIT NO. 16-371-30

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

| Material                            | Water Strata | From | To  | Thick-ness |
|-------------------------------------|--------------|------|-----|------------|
| LARGE OBSIDIAN BOULDERS AND COBBLES |              | 0    | 21  | 21         |
| COBBLES AND GRAVELS                 |              | 21   | 110 | 89         |
| BROWN CLAY                          |              | 110  | 145 | 35         |
| SMALL SANDS AND CLAY                |              | 145  | 165 | 20         |
| BROWN CLAY                          |              | 165  | 193 | 28         |
| FRACTURED GRAVELS                   | XXX          | 193  | 220 | 27         |

RECEIVED  
 OCT - 1 AM 11 13  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 220 Feet Depth Cased 220 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
10 5/8 Inches 0 Feet 220 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet)  |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 5/8</u>       | <u>13.03</u>        | <u>.188</u>             | <u>0</u>    | <u>220</u> |

Perforations:  
 Type perforation FACTORY MILL SLOT  
 Size perforation 3 X 3/32  
 From 200 feet to 220 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 220 feet

9. WATER LEVEL  
 Static water level 95 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 25+ P.S.I.  
 Water temperature COLD °F Quality GOOD

Date started 9/24, 20 04  
 Date completed 9/25, 20 04

7. WELL TEST DATE

| TEST METHOD: | Bailer                        | Pump                     | Air Lift                            |
|--------------|-------------------------------|--------------------------|-------------------------------------|
|              | <input type="checkbox"/>      | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| G.P.M.       | Draw Down (Feet Below Static) |                          | Time (Hours)                        |
| <u>25+</u>   | <u>35</u>                     |                          | <u>3 HRS</u>                        |

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name CAPITAL CITY WELL DRILLING  
 (CONTRACTOR)  
 Address 20 KIT KAT DRIVE  
 (CONTRACTOR)  
CARSON CITY, NV 89706  
 Nevada contractor's license number issued by the State Contractor's Board 0055548  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157  
 Signed Rick Crane  
 By driller performing actual drilling on site or contractor  
 Date 9/26/04