WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95460
Permit No.
Basin 71

NOTICE OF INTENT NO. 52526

1. OWNER Brooks, Jeff & Kim
MAILING ADDRESS 3320 East Donald Lane Winnemucca, NV 89445
ADDRESS AT WELL LOCATION 3320 East Donald Lane

2. LOCATION ¼ SE ¼ Sec. 25 T. 35 N/S R. 37 E. Humboldt County
PERMIT NO. N/A (Issued by Water Resources) Out-of parcel map- Don Woods. (Parcel No.) 014-153-04 (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	5	5
Sand + Gravel		5	55	50
Clay		55	90	35
Gravel + Sand		90	110	20
Clay		110	140	30
Gravel + Cobbles		140	150	
Clay		150	160	10
Sand + Gravel		160	175	15
Clay		175	180	5
Gravel + Sand	—	180	200	20

RECEIVED 04 OCT -1 AM 11:14 STATE ENGINEERS OFFICE

Date started Sept 25 2004
Date completed Sept 26 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		5

8. WELL CONSTRUCTION
Depth Drilled 200' Feet Depth Cased 198 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10 5/8	0	200

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	.188	+1	198

Perforations:
Type perforation Factor Cut
Size perforation 3/32 x 4
From 198 feet to 165 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 198 feet

9. WATER LEVEL
Static water level 130' feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson & Sons Drilling (Contractor)
Address 10760 Grass Valley Rd (Contractor)
Win NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2053
Signed (By driller performing actual drilling on site or contractor)
Date Sept 27, 2004

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (D)-027