WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95461
Permit No.
Basin 103

NOTICE OF INTENT NO. 52228

1. OWNER Craig & Linda Wear
MAILING ADDRESS 421 Riparian Way
Carson, NV 89701

ADDRESS AT WELL LOCATION 1780 Deer Run Carson
City

2. LOCATION SW 1/4 NE 1/4 Sec. 23 T 15N N/S R 20E E Carson County
PERMIT NO. Issued by Water Resources
10-096-03 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown sand		0	15	14
Brown and gray coarse sand		15	35	20
Brown clay some sand		35	55	20
Brown granite some gravel	x	55	75	20
Brown granite brown and gray clay		75	97	22
Granite fractured	x	97	155	58
Black rock fractured	x	155	194	39

Date started 10/14/2004, 19__
Date completed 10/21/2004, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
75+		3

8. WELL CONSTRUCTION
Depth Drilled 194 Feet Depth Cased 194 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	194	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	194

Perforations:
Type perforation Machine cut
Size perforation 3/32 x 3
From 154 feet to 194 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 57
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 57 feet to 194 feet

9. WATER LEVEL
Static water level 116 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 119 °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2010
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 10/22/2004

USE ADDITIONAL SHEETS IF NECESSARY