WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95464
Permit No.
Basin 029

NOTICE OF INTENT NO. 53057

1. OWNER GOLDEN EAGLE FARMS - NILS NILSON
MAILING ADDRESS HCR2 BOX 394
WINNEMUCCA, NV 89445

ADDRESS AT WELL LOCATION GOLDEN EAGLE RANCH

2. LOCATION NE 1/4 NW 1/4 Sec. 36 T 44N N/S R 31 E HUMBOLDT County
PERMIT NO. _____ Issued by Water Resources | Parcel No. 02-291-19 | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| DECOMPOSED GRANITE | | 0 | 30 | 30 |
| DECOMPOSED GRANITE | | 30 | | |
| W/COBBLES | | | 50 | 20 |
| CLAY | | 50 | 110 | 60 |
| SAND AND PEA GRAVEL | | 110 | 120 | 20 |
| DECOMPOSED GRANITE AND | | 120 | | |
| SAND | | | 135 | 15 |
| CLAY | | 135 | 145 | 10 |
| DECOMPOSED GRANITE | | 145 | 170 | 25 |
| SANDY CLAY | | 170 | 210 | 40 |
| SAND | | 210 | 220 | 10 |
| SANDY CLAY | | 220 | 270 | 50 |
| BROWN CLAY | | 270 | 273 | 3 |
| SANDY CLAY | | 273 | 275 | 2 |
| GRANITE SAND | | 275 | 285 | 10 |
| COARSE SAND | | 285 | 300 | 15 |

RECEIVED 04 OCT 21 AM 11:05 STATE ENGINEERS OFFICE

Date started 10/14/04, 19__
Date completed 10/14/04, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| 10/14/04 | 50 | | 2 HRS |

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 3/4 | Inches | 0 Feet | 300 Feet |
| | Inches | Feet | Feet |
| | Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | | .188 | +2 | 240 |
| | | | | |
| | | | | |

Perforations:
Type perforation MILL SLOT
Size perforation .090
From 240 feet to 300 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 75'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 75 feet to 300 feet

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature COOL °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4975 W. Winnemucca Blvd (Contractor)
Winnemucca, Nevada 89445
Nevada contractor's license number issued by the State Contractor's Board 56797
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 10/19/20