WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95471
Permit No.
Basin 042

NOTICE OF INTENT NO. 49072

1. OWNER LOUIE GIANCANELLI
MAILING ADDRESS 15043 LOCKWOOD VALLEY
FRAIZER, CA 93225

ADDRESS AT WELL LOCATION COUNTY ROAD 754

2. LOCATION SE 1/4 NW 1/4 Sec. 20 T 39N N/S R 63 E ELKO County
PERMIT NO. (Issued by Water Resources) 008-360-009 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SUB SOIL		0	5	5
GRAVEL		5	90	85
TAN COLORED CLAY		90	100	10
GRAVEL	X	100	125	25
GRAVEL & FINE SAND	X	125	160	35
FINE SAND	X	160	191	31
GRAVEL	X	191	200	9
HARD BLACK ROCK		200	205	5

RECEIVED OCT 21 2004 STATE ENGINEERS OFFICE

Date started 10/5/2004, 19__
Date completed 10/8/2004, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	25		6.5

8. WELL CONSTRUCTION
Depth Drilled ~~220~~ 205 Feet Depth Cased ~~220~~ 205 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	205	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+1	24'
6	SDR17		24'	205

Perforations:
Type perforation MILL CUT
Size perforation 1/8X3
From 185 feet to 205 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal 52
Placement Method: [ ] Pumped [X] Poured
Gravel Packed: [ ] Yes [X] No
From 52 feet to 205 feet

Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout
Bentonite Grout 24-52

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SHAREL C. FERTIG SR., DBA FERTIG DRILLING CO. (Contractor)
Address P.O. BOX 525 (Contractor)
ELKO, NEVADA 89803
Nevada contractor's license number issued by the State Contractor's Board 031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed (By driller performing actual drilling on-site or contractor)
Date 10/20/2004

USE ADDITIONAL SHEETS IF NECESSARY