

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 95472  
 Permit No. \_\_\_\_\_  
 Basin 049

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34272

1. OWNER **UBALDO GONZALES**  
 MAILING ADDRESS **703 LAST CHANCE ROAD #8**  
**ELKO, NV 89802**

ADDRESS AT WELL LOCATION **LOT 14, BLOCK A BUZZARD**  
**WAY**

2. LOCATION SW 1/4 SE 1/4 Sec. 12 T 34N  
 PERMIT NO. 032-001-014  
 Issued by Water Resources Parcel No. Subdivision Name

N/S R 55E E ELKO County

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
LOOSE SUB SOIL		0	10	10
SAND & GRAVEL		10	37	27
CLAY		37	151	114
SAND/GRAVEL		151	152	1
CALACHE CLAY		152	206	54
SAND & GRAVEL	X	207	207	
ROCK & GRAVEL	X	281	285	4
CALACHE CLAY		285	360	75
SOFT BROWN CLAY		360	400	40

8. WELL CONSTRUCTION

Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
10	0	400

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	1	19
6	SDR17		19	400

Perforations:

Type perforation MILL SLOT  
 Size perforation 1/8X3

From	To
<u>340</u> feet	<u>380</u> feet
_____ feet	_____ feet
_____ feet	_____ feet
_____ feet	_____ feet
_____ feet	_____ feet

Surface Seal:  Yes  No  
 Depth of Seal 54  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 54 feet to 400

Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
BENTONITE GROUT  
18'-54' feet

9. WATER LEVEL  
 Static water level 167 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name SHAREL C. FERTIG SR., DBA FERTIG DRILLING CO  
 Contractor  
 Address P.O. BOX 525  
 Contractor  
ELKO, NEVADA 89803  
 Nevada contractor's license number issued by the State Contractor's Board 31904  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 7584  
 Signed [Signature]  
 By driller performing actual drilling on-site or contractor  
 Date 10/20/2004

Date started 10/12/2004, 19  
 Date completed 10/15/2004, 19

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>APPROX 30</u>		

RECEIVED  
 OCTOBER 21 2004  
 STATE ENGINEERS OFFICE