

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 95479
 Permit No. _____
 Basin 101

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 53804

1. OWNER Lee Hutchens
 MAILING ADDRESS 2152 Reno hwy
Fallon, NV 89407
 ADDRESS AT WELL LOCATION Lee Hutchens
4439 Rancheria Drive
Fallon, NV

2. LOCATION SW $\frac{1}{4}$ se $\frac{1}{4}$ Sec 16 T 19 N R 28 E Churchill County
 PERMIT NO. 009-122-29

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown sand		0	3	3
Brown Clay		3	25	22
Brown Sand		25	42	17
Gray Clay		42	44	2
Gray Sand		44	50	6
Brown Sand		50	53	3
Gray Clay		53	56	3
Gray Sand		56	57	1
Black Clay		57	58	1
Black Sand		58	60	2
Black Clay		60	65	5
Black Sand		65	80	15
Brown Clay		80	81	1
Brown Sand		81	105	24
Gray Sand		105	108	3
Brown Sand		108	115	7
Gray Sand		115	125	10
Black Clay		125	140	15
Black Sand		140	150	10
Gray Clay		150	155	5
Gray Sand		155	165	10
Gray Clay		165	170	5
Gray Sand		170	180	10
Gray Clay		180	182	2
Black Clay		182	185	3
brown Clay		185	195	10
brown Sand	XXX	195	205	10

8. WELL CONSTRUCTION
 Depth Drilled 205 Feet Depth Cased 205 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10 Inches 0 Feet 205 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6 pvc	3.82	.258	20	205

Perforations:
 Type perforation Saw Cut
 Size perforation 1/8
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 205 feet

9. WATER LEVEL
 Static water level 34 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Parsons Drilling Inc
 (CONTRACTOR)

Address P.O. Box 1265
 (CONTRACTOR)
Fallon, NV 89407-1265
 Nevada contractor's license number issued by the State Contractor's Board 29064
 Nevada driller's license number issued by the Division of Water Resources, on site driller 1454

Signed Norman Parson
 By driller performing actual drilling on site or contractor
 Date 11/5/04

Date started 09/27, 20 04
 Date completed 09/28, 20 04

7. WELL TEST DATE

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	