

Log No. 95483  
 Permit No. 51478  
 Basin 078

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 53860

1. OWNER NEW MONT MINING ADDRESS AT WELL LOCATION TRINITY PROJECT  
 MAILING ADDRESS P.O. Box 388 LOVELOCK NV.  
Valley, NV 89438  
 2. LOCATION S W 1/4 SE 1/4 Sec 9 T 29 @ R 30 E PERSHING County  
 PERMIT NO. Issued by water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
INTERED WELL TO DEPTH OF 120' AND REFORATE TO 150'		120'	150'	30'
TRIPPER TO 650' PUMPED SUPER PLUG UNTILL CIRC. 122 BAGS AT 50 LB. TO 60'		650'	60'	590'
KWIK DRG 3/8 CHIPS 8, 50 LB. BAGS		60'	52'	8'
NEAT CEMENT 20-44 LB. MASS NEVADA CEMENT		52'	0'	52'

8. WELL CONSTRUCTION  
 Depth Drilled 695' Feet Depth Cased 660' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
 Inches Feet Feet  
 Inches Feet Feet  
 Inches Feet Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8"</u>		<u>1/4"</u>	<u>0'</u>	<u>156'</u>

 Perforations:  
 Type perforation UNKNOWN  
 Size perforation  
 From 156' feet to 660' feet  
 From feet to feet  
 From feet to feet  
 From feet to feet  
 From feet to feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 52'  Neat Cement  
 Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From \*\*\* feet to feet

Date started 10-20-04, 20  
 Date completed 10-21-04, 20

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
<u>N/A</u>			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
*Note: See logs 29504 & 112327			

9. WATER LEVEL  
 Static water level 125' feet below land surface  
 Artesian flow G.P.M. P.S.I.  
 Water temperature °F Quality

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Jay Jayne Harris Contractor  
 Address EKLOND DRILLING CO. Contractor  
P.O. BOX 2748 ELKO NV. 89803  
 Nevada contractor's license number issued by the State Contractor's Board 0030823  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1698  
 Signed Jay Jayne Harris  
 By driller performing actual drilling on site or contractor  
 Date 11-8-04