

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**



OFFICE USE ONLY  
 Log No. 95490  
 Permit No. \_\_\_\_\_  
 Basin 248

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49643

1. OWNER Spring Creek Association ADDRESS AT WELL LOCATION 390 Oakshire Dr. Spring Creek, NV 89815  
 MAILING ADDRESS 451 Spring CK Pkwy Spring CK, NV 89815

2. LOCATION SW 1/4 SE 1/4 Sec 18 T. 33 N/S R. 57 E County Elko  
 PERMIT NO. 78890 Lot/Parcel No. Lot 1 BIK 4 NDEP Facility ID 6-000320 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>MW-03</u>				
<u>pulled casing + slotted PVC</u>				
<u>per NAC 534.4365 &amp; subsection 4 of NAC 534.4371</u>				
<u>using Na-bentonite chips</u>				

8. WELL CONSTRUCTION  
 Depth Drilled 24 Feet Depth Cased 24 Feet

HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet \_\_\_\_\_  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet \_\_\_\_\_  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet \_\_\_\_\_

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>shed 40</u>	<u>PVC</u>	<u>0</u>	<u>14</u>

Perforations:  
 Type perforation factory slotted  
 Size perforation 0.020"  
 From 14 feet to 24 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 0-24 w/ sodium bentonite chips  Neat Cement  
 Placement Method:  Pumped  Poured  Cement Grout  Concrete Grout

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 15 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started December 10, 2004  
 Date completed December 10, 2004

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Peter Herrera  
 Address 9424 Warehouse Pl. Las Vegas, NV 89123  
 Nevada contractor's license number issued by the State Contractor's Board 14291  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2241  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 12-15-04