MW-11

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95495
Permit No.
Basin 842

NOTICE OF INTENT NO. 54932

1. OWNER Fearless Farris Corporation
MAILING ADDRESS P.O. Box 7627
Boise Idaho 83707

ADDRESS AT WELL LOCATION 1010 Sixth Street
Wells Nevada

2. LOCATION NW ¼ SE ¼ Sec. 10 T. 37 N. S R. 62 E Elko County
PERMIT NO. M/O-1345 (Issued by Water Resources) 002-760-001 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Direct Push

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| asphalt | | 0 | .3 | |
| Brown Gravelly Sand | | .3 | 3.5 | |
| Brown Clayey Sand | | 3.5 | 6.3 | |
| Gray Silty Sand | | 6.3 | 10 | |
| Clayey Sand Gray | | 10 | 11.5 | |
| Clayey Gravelly Sand Gray | | 11.5 | 12 | |
| Gray Clayey Sand | | 12 | 13 | |
| Clayey Gravelly Sand Gray | | 13 | 15.0 | |
| GPS | | | | |
| UT 0671273 | | | | |
| UTM 4552142 | | | | |

Date started Dec. 14, 2004
Date completed Dec. 14, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| | | | |

8. WELL CONSTRUCTION
Depth Drilled 15 Feet Depth Cased 15 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 | Inches | 0 Feet | 1 Feet |
| 3.5 | Inches | 1 Feet | 3 Feet |
| | Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 1.875 | | Sch 40 PVC | .25 | 5 |

Perforations:
Type perforation Factory Slotted (PVC)
Size perforation
From 5 feet to 15 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 2-3 Bentonite
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
0-1 Flush Completion
Gravel Packed: ☒ Yes ☐ No
From 3 (10-20 feet to 15 feet

9. WATER LEVEL
Static water level 11.63 BGS feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Layne Christensen Company (Contractor)
Address 4490 West 1707 South (Contractor)
Salt Lake City, Utah 84104
Nevada contractor's license number issued by the State Contractor's Board 0019101
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1970
Signed Wilburn L. Franklin (By driller performing actual drilling on site or contractor)
Date Dec. 14, 2004

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627