


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 95508
 Permit No. _____
 Basin 162



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28164

1. OWNER HORTON LOVEJOY ADDRESS AT WELL LOCATION 1390 W. FRANCINE ST
 MAILING ADDRESS 1390 W. FRANCINE ST
PAHRUMP, NV

2. LOCATION SW 1/4 NE 1/4 Sec. 32 T 19S N/S R 53E E NYE County
 PERMIT NO. 41-591-20 Parcel No. GOLDEN SPRINGS RANCH UNIT 7 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	6	6
CALICHE		6	24	18
CLAY		24	60	36
CALICHE	WB	60	75	15
CLAY		75	115	40
CALICHE	WB	115	128	13
CLAY		128	145	17
CALICHE	WB	145	160	15
CLAY		160	170	10
CALICHE		170	180	10

DCNR/DWR RECEIVED
MAR 28 2005
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 180 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	180

Perforations:
 Type perforation SAWCUT
 Size perforation 1/8 X 3


From 120 feet to 180 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 _____ Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 180 feet

9. WATER LEVEL
 Static water level 55 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor

Address P.O. BOX 4220 Contractor
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board 47333
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
 Signed 
 By driller performing actual drilling on-site or contractor
 Date 3/21/05

Date started 3/14/2005 .19
 Date completed 3/14/2005 .19

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailer			
<input type="checkbox"/> Pump			
<input type="checkbox"/> Air Lift			