WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95540
Permit No.
Basin 101

NOTICE OF INTENT NO. 53811

1. OWNER LUMAS + ASSOCIATES INC.
MAILING ADDRESS ~~RENO~~ 5401 LONGLEY LANE, SUITES, RENO, NV 89511

ADDRESS AT WELL LOCATION 111 RENO HIGHWAY HAZEN, NV

2. LOCATION NW ¼ SE ¼ Sec. 1 T. 19 N/S R. 26 E. CHURCHILL County

PERMIT NO. Issued by Water Resources | 09-271-26 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other SONIC

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	45	
SAND		45	60	
CLAY		60	70	
GRAVEL		70	80	
CLAY		80	115	
SAND		115	125	
GRAVEL		125	140	
CLAY		140	195	
GRAVEL		195	220	
CLAY		220	245	
SILTY CLAY		245	270	
SAND		270	275	
SILTY CLAY		275	280	
SAND		280	285	
CLAYEY GRAVEL		285	295	
CLAY		295	305	
SAND		305	340	
GRAVEL		340	400	

RECEIVED
01 DEC -1 AM 10:23
STATE ENGINEER'S OFFICE

DUNA/DAAH
RECEIVED
NOV 2 2 2004
LAS VEGAS OFFICE

Date started 8/29, 2004
Date completed 9/12, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	250 Feet
6 Inches	250 Feet	400 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4	2	0.237	0	250

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 200 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 192'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 195 feet to 250 feet

9. WATER LEVEL
Static water level 5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name PROSONIC CORPORATION (Contractor)
Address 419 E. JUANITA AVE. (Contractor)
MESA, AZ 85204
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2249
Signed [signature] By driller performing actual drilling on site or contractor
Date 10/8/04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627