

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 95541  
 Permit No. \_\_\_\_\_  
 Basin 173B

NOTICE OF INTENT NO. 51399

1. OWNER Duckwater Shoshone Tribe ADDRESS AT WELL LOCATION Eugene Hooper Residence  
 MAILING ADDRESS P.O. Box 140068  
Duckwater, Nevada 89314

2. LOCATION NW 1/4 SW 1/4 Sec 7 T 12 N 5 R 56 E Nye County

PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

| Material                | Water Strata | From | To  | Thick-ness |
|-------------------------|--------------|------|-----|------------|
| Sand                    |              | 0    | 14  | 14         |
| Clay                    |              | 14   | 16  | 2          |
| Volcanic Boulders       | X            | 16   | 21  | 5          |
| Solid Volcanics         |              | 21   | 31  | 10         |
| Boulders                | X            | 31   | 33  | 2          |
| Clay                    |              | 33   | 48  | 15         |
| Clay & Gravel           |              | 48   | 53  | 5          |
| Clay                    |              | 53   | 68  | 15         |
| Clay & Gravel           |              | 68   | 100 | 32         |
| Clay with Water Bearing | X            | 100  |     |            |
| Sand & Gravel Stringers |              |      | 142 | 42         |

8. WELL CONSTRUCTION  
 Depth Drilled 142 Feet Depth Cased 142 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 142 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6-5/8              | 12.92               | .188                    | 0           | 142       |

Perforations: Factory  
 Type perforation \_\_\_\_\_  
 Size perforation 1/8" X 2 1/2" 6 Rows  
 From 62 feet to 142 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50 Feet  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 142 feet

9. WATER LEVEL  
 Static water level 21 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Christiansen Drilling, Inc. Contractor  
 Address 557 Ely Avenue Contractor  
Ely, Nevada 89301

Nevada contractor's license number issued by the State Contractor's Board 14790  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793

Signed Jerrold D. Christiansen - Rick Lewis  
 By driller performing actual drilling on site or contractor  
 Date November 29, 2004

Date started November 9 2004  
 Date completed November 18 2004

7. WELL TEST DATA  
 TEST METHOD:  Bailer  Pump  Air Lift

|                 | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|-----------------|--------|-------------------------------|--------------|
| Sub Pump        |        |                               |              |
| Set @ 135'      | 9      | 64                            | 28 Minutes   |
|                 | 9      | 69                            | 3 Minutes    |
|                 | 8      | 79                            | 10 Minutes   |
|                 | 7 1/2  | 94                            | 14 Minutes   |
| Pumped Off      | 7 1/2  | 114                           | 8 Minutes    |
| Total Pump Time |        |                               | 1 Hour       |

Recharge Back to 68' in 1 Hour

RECEIVED  
 OCT 31 11:21:07  
 WELL DRILLERS OFFICE

1 H.P.