

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 96553  
 Permit No. \_\_\_\_\_  
 Basin B418

NOTICE OF INTENT NO. 49643

1. OWNER Spring Creek Association ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 451 Spring Creek Pkwy 390 Oakshire Dr.  
Spring Creek, NV 89815 Spring Creek, NV 89815  
 2. LOCATION SW 1/4 SE 1/4 Sec. 18 T. 33 N. S. R. 57 E. E1K0 County \_\_\_\_\_  
 PERMIT NO. 70004 Lot 1 Block 4 NDEP Facility No. 6-000370  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>PMW-07</u>				
<u>Pulled casing + slotted PVC</u>				
<u>NAC 534.4365 33 4</u>				
<u>per NAC 534.4371</u>				
<u>using sodium bentonite chips</u>				

8. WELL CONSTRUCTION  
 Depth Drilled 24 Feet Depth Cased 22 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>	<u>Sched 40</u>	<u>PVC</u>	<u>0</u>	<u>12</u>

Perforations:  
 Type perforation Factory slotted  
 Size perforation 0.020"  
 From 12 feet to 22 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 0-22' sodium bentonite  Neat Cement  
 Placement Method:  Pumped Chips  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 15 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started December 10, 2004  
 Date completed December 10, 2004

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name PETE HERRERA  
 Address 9424 Warehouse Pl  
Las Vegas, NV 89123  
 Nevada contractor's license number 14291  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the 2241  
 Division of Water Resources, the on-site driller.  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 12-15-04