WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95561
Permit No.
Basin 087

NOTICE OF INTENT NO. 49572

1. OWNER Hidden Valley Country Club
MAILING ADDRESS 3575 Hidden Valley Drive
Reno, NV

ADDRESS AT WELL LOCATION Hidden Valley Golf Course maintainence building

2. LOCATION NE 1/4 SE 1/4 Sec. 27 T 19N N/S R 20E E Washoe County
PERMIT NO. n/a (Issued by Water Resources) n/a (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Measured 4, 4" monitor wells depths at 50',50',50' and 60'. Static water levels were 36',36', 38' and 38.4'. Installed 1-1/2" tremme pipe and mixed approximately 25 bags of Portland Type II cement with 125 gallons of water and pumped in from bottom of well to surface. Well volumes should have required approximately 19 cubic feet but actually used approx. 28 cubic feet of neat cement. Monitor well vaults were removed and casing cut off 2' below ground surface and back filled to ground level.				

RECEIVED 04 NOV 30 AM 11:14 WATER ENGINEERING OFFICE

Date started , 19
Date completed , 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	pvc	Sch.40	gl	60'

Perforations:
Type perforation slotted
Size perforation .020
From 50 feet to 60 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level see comments feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Carson Pump (Contractor)
Address P.O. Box 20159 (Contractor)
Carson City, NV. 89721
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed Dan Trampe (By driller performing actual drilling on-site or contractor)
Date 11/26/2004

USE ADDITIONAL SHEETS IF NECESSARY