


COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**



OFFICE USE ONLY

Log No. 95578  
 Permit No. 53530  
 Basin 105 46258  
 NOTICE OF INTENT NO. 93526

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER GARY LIST VERUS CONSTRUCTION ADDRESS AT WELL LOCATION 1678 SOUTH BENTON RD  
 MAILING ADDRESS 1615 HWY 395 NORTH GARDNERVILLE, NV 89410  
MINDEN, NV 89403

2. LOCATION NE 1/4 NE 1/4 Sec 26 T 13 N R 20 E DOUGLAS County

PERMIT NO. 1320-26-002-051

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVER BURDEN		0	3	3
HARD PAN CLAY		3	9	6
COURSE DG GRAVELS		9	45	36
BROWN CLAY		45	110	65
SMALL OBSIDIAN GRAVELS		110	162	52
BROWN GUMMY CLAY		162	203	41
FRACTURED GRAVELS				
SMALL SILTY SAND LAYERS	XXX	203	240	37

8. WELL CONSTRUCTION

Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>10 3/4</u> Inches	<u>0</u> Feet <u>240</u> Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>240</u>

Perforations:

Type perforation FACTORY MILL SLOT  
 Size perforation 3 X 3/32

From	To
<u>220</u> feet to <u>240</u> feet	
_____ feet to _____ feet	
_____ feet to _____ feet	
_____ feet to _____ feet	
_____ feet to _____ feet	

Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 100  Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured

Gravel Packed:  Yes  No  
 From 100 feet to 240 feet

Date started 10/4, 20 04  
 Date completed 10/5, 20 04

7. WELL TEST DATE

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>65</u>	<u>3 HRS</u>
_____	_____	_____
_____	_____	_____

9. WATER LEVEL  
 Static water level 80 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 25 P.S.I.  
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name CAPITAL CITY WELL DRILLING  
 (CONTRACTOR)  
 Address 20 KIT KAT DRIVE  
 (CONTRACTOR)  
CARSON CITY, NV 89410  
 Nevada contractor's license number issued by the State Contractor's Board 0055548  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157

Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 10/4/04

RECEIVED  
 04 NOV - 5 AM 11:20  
 STATE ENGINEERS OFFICE

DCNR/DWR  
 RECEIVED  
 JAN 20 2005

LAS VEGAS OFFICE