WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95606
Permit No.
Basin 101

NOTICE OF INTENT NO. ~~53067~~ 53093

1. OWNER CASEY PROPERTIES
MAILING ADDRESS 4240 RENO HWY
FALLON, NV 89406

ADDRESS AT WELL LOCATION 7155 ANNETTE

2. LOCATION ~~SE~~ 1/4 ~~SW~~ 1/4 Sec. 1 T 19 N/S R 27 E CHURCHILL County
PERMIT NO. NW SE (Issued by Water Resources) 007-122-22 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| TOP SOIL | | 0 | 179 | 179 |
| BROWN SAND | | 1 | 20 | 19 |
| BROWN CLAY | | 20 | 28 | 8 |
| BROWN SAND | | 28 | 38 | 10 |
| GRAY CLAY/SAND | | 38 | 60 | 22 |
| GRAY SAND | | 60 | 100 | 40 |
| GRAY CLAY | | 100 | 115 | 15 |
| GRAY SAND | | 115 | 150 | 35 |
| GRAY CLAY | | 150 | 155 | 5 |
| GRAY SAND | | 155 | 170 | 15 |
| GRAY CLAY | | 170 | 179 | 9 |
| BROWN SAND | X | 179 | 194 | 15 |

RECEIVED 04 DEC -7 AM 11:35 STATE ENGINEERS OFFICE

Date started 9/28/1994 , 19__
Date completed 10/22/1994 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| AIR LIFT | 25 | | 1 HR |

RECEIVED 05 FEB -1 AM 11:31 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
Depth Drilled ~~188~~ 194 Feet Depth Cased ~~188~~ 194 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 10 3/4 | Inches | 0 | Feet | 50 | Feet |
| 6 1/4 | Inches | 50 | Feet | ~~188~~ | Feet |
| | Inches | | Feet | 194 | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12.9 | .188 | +2 | 188 |
| | | | | |
| | | | | |

Perforations:
Type perforation MACHINE SLOT
Size perforation .080
From 178 feet to 183 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 25'4" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. (Contractor)
Address P. O. BOX 888 (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed (By driller performing actual drilling on-site or contractor)
Date 11/21/1920

USE ADDITIONAL SHEETS IF NECESSARY