COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95616
Permit No.
Basin 101

NOTICE OF INTENT NO. 54885

1. OWNER Cornerstone Construction
MAILING ADDRESS 3650 Research Way #22
Fallon, NV 8406

ADDRESS AT WELL LOCATION Cornerstone Construction
170 Winchester Dr
Fallon, NV 89406

2. LOCATION ne ¼ nw ¼ Sec 18 T 19 N R 29 E Churchill County

PERMIT NO. (Issued by Water Resources) | 007-431-33 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	4	4
Brown Clay		4	28	24
Black Sand		28	30	2
Black Clay		30	36	6
Black Sand		36	52	16
Black Clay		52	61	9
Black Sand		61	85	24
Brown Sand	XX	85	92	7

RECEIVED 05 FEB 25 AM 11:57 STATE ENGINEERS OFFICE

Date started 02/14, 20 05
Date completed 02/14, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 92 Feet Depth Cased 92 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	92 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6 pVC	3.82	.258	20	92

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 87 feet to 92 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50 ☐ Neat Cement
Placement Method: ☒ Pumped ☒ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 92 feet

9. WATER LEVEL

Static water level 8 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling Inc (CONTRACTOR)
Address P.O. Box 1265 (CONTRACTOR)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753-T1
Signed [signature] By driller performing actual drilling on site or contractor
Date 02/18/05

(Rev 12/01) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com