WELL 5-5

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95620
Permit No.
Basin 090

NOTICE OF INTENT NO. 54016

1. OWNER DENNIS BROWN, SHELL OIL PRODUCTS US
MAILING ADDRESS 20945 S, WILMINGTON AVE
CARSON, CA

ADDRESS AT WELL LOCATION
180 ~~[illegible]~~ ELKS POINT ROAD
ZEPHYR COVE (ROUNDHILL SHOPPING CENTER)

2. LOCATION NE ¼ SE ¼ Sec. 15 T. 13 N/S R 18 E DOUGLAS County

PERMIT NO. _____ Issued by Water Resources | 1378-15-810-001 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other ROTOSONIC

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT		0	0.25	0.25
Yellow brown silty Sand		0.25	12	11.75
Olive brown Sand		12.00	26	14
Olive brown Silty Sand		26	32	6
Sandy Gravel		32	34	2
Silty Sand		34	39	5
Silty Gravel		39	43	5
Silty Sand	65-70	43	71.0	28

RECEIVED
05 MAR -1 AM 10:05
STATE ENGINEERS OFFICE

Date started DECEMBER 6, 2004
Date complated DECEMBER 9, 2004

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 71.0 Feet Depth Cased 70 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	71 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.25	SCL 40	0.25	0	70

Perforations:
Type perforation SWITCH
Size perforation 0.020"
From 50 feet to 70 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 45'
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 48 feet to 71 feet

9. WATER LEVEL
Static water level 50' feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature N/A °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ROBERT SALOIS (BOART LONGYEAR CO)
Contractor

Address 7773 W. SELDON LN
Contractor

PEORIA, AZ 85345

Nevada contractor's license number issued by the State Contractor's Board 0010157

Nevada driller's license number issued by the Division of Water Resources, the on-site driller -M-2270

Signed [signature]
By driller performing actual drilling on site or contractor

Date 12-27-04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627