

Log No. _____
Permit No. _____
Basin 207

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43211

1. OWNER David Dipson ADDRESS AT WELL LOCATION Par. Bay Farms
MAILING ADDRESS Box 203
Land NV 89317

2. LOCATION Sec. 19 T. 10 N/S R. 61 E. Nye County NYE
PERMIT NO. 813-681-12 Parcel No. NONE Subdivision Name _____
Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		192	193	
Sand gravel	water	193	195	2
Clay		195	204	
Sand gravel	water	204	205	1
Clay		205	219	
gravel	water	219	220	
clay		220	245	
green clay		245	250	
tan clay		250	255	
Sand gravel	water	255	257	2
Clay		257	262	
Sand gravel	water	262	268	6
green clay		268	275	
tan clay		275	280	
green clay		280	300	
Brown clay		300	305	
grey clay		305	310	
Tan Sandy clay		310	340	

8. WELL CONSTRUCTION
Depth Drilled 340 Feet Depth Cased 304 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
24 Inches	0	304
6 Inches	304	340

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
20		.250	-1	52
16		.250	-15	304

Perforations:
Type perforation mill
Size perforation 4 x 2.5"

From _____ feet to _____ feet
From 51 feet to 304 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal _____
Placement Method: Pumped Poured
 Gravel Packed: Yes No
From 50 feet to 304 feet

9. WATER LEVEL
Static water level 2.8 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cold °F Quality good

Date started Feb 1 2005
Date completed March 15 2005

7. WELL TEST DATA

TEST METHOD: Bailers Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
		1.5

RECEIVED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Maynard Well Drilling Contractor
Address PO Box 64 Land NV 89317 Contractor

Nevada contractor's license number issued by the State Contractor's Board 047226
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556

Signed Owner Maynard
By driller performing actual drilling on site or contractor
Date March 18 - 05