REPORT NO. A05.014

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 95637
PERMIT NO.
BASIN 87

NOTICE OF INTENT NO. 54960

1. OWNER Coral Paris
MAILING ADDRESS 8420 Leroy St. Reno, NV 89523
ADDRESS OF WELL 8420 Leroy St.
Reno, NV 89523

2. WELL LOCATION NW 1/4 SW 1/4 SEC. 18 T 19 R 19 E Washoe COUNTY
PERMIT NO PARCEL NO 39-141-03 SUBDIVISION NAME

3. TYPE OF WORK
[ ] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS

RECEIVED
05 MAR 29 AM 10:55
STATE ENGINEER'S OFFICE

Notes: Perforated from 273' to ground level. No sanitary seal. Pumped neat cement from 273' to ground level. Cut casing off. Lat: N 39 30.740 Long: W 119 53.985

Date Started 3/9/05 Date Completed 3/9/05

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [ ] Air Develop

	GPM	DRAWDOWN	TIME (HRS)

8. WELL CONSTRUCTION
Depth Drilled Depth Cased

HOLE DIAMETER (BIT SIZE)
6 5/8 Inches Feet Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To

PERFORATIONS:
Type Perforation Size Perforation
From Feet to Feet
From Feet to Feet
From Feet to Feet

SURFACE SEAL: [ ] Yes [ ] No
SEAL TYPE: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout [ ] Bentonite
Seal Depth
PLACEMENT METHOD: [ ] Pumped [ ] Poured
GRAVEL PACKED: [ ] Yes [ ] No
From Feet to Feet

9. WATER LEVEL
Static Water Level 45 Feet Below Land Surface
Artesian Flow GPM PSI
Water Temperature F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.
Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno, NV 89502
NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. ON SITE 2189
Signed
By driller performing actual drilling on site or contractor
Dated March 9, 2005