WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95651
Permit No.
Basin 105

NOTICE OF INTENT NO. 54015

1. OWNER Katsaris Construction
MAILING ADDRESS 2991 Hot Springs Road
Minden, NV 89423

ADDRESS AT WELL LOCATION 1823 Long Court,
Gardnerville, NV

2. LOCATION NW 1/4 SW 1/4 Sec. 24 T 12N N/S R 20E E Douglas County
PERMIT NO. _____ Issued by Water Resources
1220-24-302-008 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

6. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Small rock coarse sand		0	26	26
Gravel, boulders		26	42	16
Coarse sand, gravel, boulders		42	65	23
Coarse sand some rock		65	90	25
Boulders coarse sand		90	106	16
Coarse sand some rock		106	158	52

RECEIVED
05 JAN 10 AM 8:26
STATE ENGINEER'S OFFICE

Date started 12/22/2004, 19__
Date completed 12/27/2004, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		3 hrs.

8. WELL CONSTRUCTION
Depth Drilled 158 Feet Depth Cased 158 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	158 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	158

Perforations:
Type perforation Machine cut
Size perforation 3/32 X 3
From 138 feet to 158 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 158 feet

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2205
Signed R. Bruce MacKay By driller performing actual drilling on-site or contractor
Date 12/29/2004

USE ADDITIONAL SHEETS IF NECESSARY