

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT



OFFICE USE ONLY

95655

Dog No.

Permit No.

Basin

101

NOTICE OF INTENT NO. 55119

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER **Hawk Properties**
 MAILING ADDRESS **2171 W Williams Ave. Fallon, NV 89406**
 ADDRESS AT WELL LOCATION **Hawk Properties 4511 Hawk Drive Fallon, NV 89406**

2. LOCATION sw $\frac{1}{4}$ se $\frac{1}{4}$ Sec 21 T 19 N R 28 E **Churchill** County

PERMIT NO. **008-282-16**

Issued by Water Resources

Parcel No.

Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	2	2
Brown clay		2	16	14
Brown sand		16	31	15
Gray Clay		31	34	3
Gray Sand		34	39	5
Black Clay		39	42	3
Black Sand		42	53	11
Brown Clay		53	55	2
Brown Sand	XX	55	61	6

RECEIVED
 05 MAR 28 PM 11:22
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION

Depth Drilled 61 Feet Depth Cased 61 Feet

HOLE DIAMETER (BIT SIZE)

From	To
10 Inches	0 Feet 61 Feet
Inches	Feet Feet
Inches	Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6 pVC	3.82	.258	20	61

Perforations:

Type perforation **Saw Cut**
 Size perforation **1/8**

From 58 feet to 61 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 61 feet

9. WATER LEVEL

Static water level 10 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality unknown

Date started 02/28, 20 05
 Date completed 02/28, 20 05

7. WELL TEST DATE

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>10</u>		<u>1hr</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Parsons Drilling Inc** (CONTRACTOR)
 Address **P.O. Box 1265** (CONTRACTOR)
Fallon, NV 89407-1265
 Nevada contractor's license number issued by the State Contractor's Board **29064**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1753-T1**

Signed *Chad P. M.*
 By driller performing actual drilling on site or contractor
 Date 03/24/05