REPORT NO. A05.010

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 95682
PERMIT NO.
BASIN 87

NOTICE OF INTENT NO. 54958

1. OWNER Frank Lepori
MAILING ADDRESS 1475 Hymer Ave Sparks, NV 89431
ADDRESS OF WELL 1125 N. Mccarran Blvd.
Sparks, NV 89431

2. WELL LOCATION SE 1/4 NE 1/4 SEC. 4 T 19 R 20 E Washoe COUNTY
PERMIT NO PARCEL NO 33-103-04 SUBDIVISION NAME

3. TYPE OF WORK
[ ] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS

RECEIVED
05 MAR -7 PM 1:57
STATE ENGINEERS OFFICE

Notes: **Checked TD of 42'. Perferated 42' of casing, ran trimmie tube to total depth, pumped full of neat cement from total depth to surface. Cut casing off 3' below ground level. See original well log for sanitary seal.**

Date Started 2/24/05 Date Completed 2/24/05

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [ ] Air Develop

	GPM	DRAWDOWN	TIME (HRS)

8. WELL CONSTRUCTION
Depth Drilled Depth Cased

HOLE DIAMETER (BIT SIZE)
Inches Feet Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8	14.98	.219	GL	42

PERFORATIONS:
Type Perforation Size Perforation
From Feet to Feet
From Feet to Feet
From Feet to Feet

SURFACE SEAL: [ ] Yes [ ] No
Seal Depth
PLACEMENT METHOD: [ ] Pumped [ ] Poured
SEAL TYPE: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout [ ] Bentonite
GRAVEL PACKED: [ ] Yes [ ] No
From Feet to Feet

9. WATER LEVEL
Static Water Level 10 Feet Below Land Surface
Artesian Flow GPM PSI
Water Temperature F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.
Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno, NV 89502
NV. CONTRACTOR'S LIC. NO 15291 DRILLER'S LIC. NO. ON SITE 1981
Signed
By driller performing actual drilling on site or contractor
Dated February 24, 2005