



Log No. 95686  
 Permit No. \_\_\_\_\_  
 Basin 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 54082

1. OWNER meerscheijt/Able well ADDRESS AT WELL LOCATION Quail Run  
Grizzards Ln. 57 Quail Valley, NV  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION NW 1/4 NW 1/4 Sec. 13 T. 13 N/S R. 20 E Douglas County  
 PERMIT NO. 1320-13-000-004 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>D. G. Clay &amp; Boulders</u>		<u>0</u>	<u>200</u>	
<u>Clay</u>		<u>200</u>	<u>240</u>	
<u>Small gravel &amp; sand</u>		<u>240</u>	<u>270</u>	
<u>Clay &amp; pg</u>		<u>280</u>	<u>380</u>	
<u>Sand &amp; small gravel</u>		<u>380</u>	<u>400</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 400 Feet Depth Cased 400 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Feet 400 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>1 5/8</u>	<u>± 2</u>	<u>400</u>

Perforations:  
 Type perforation factory milled  
 Size perforation 3/32  
 From 240 feet to 260 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 300 feet to 320 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 380 feet to 400 feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 60 Ft  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 0 feet to 400 feet

9. WATER LEVEL  
 Static water level 190 feet below land surface  
 Artesian flow NA G.P.M. NA P.S.I.  
 Water temperature 60.1 °F Quality Clear

10. DRILLER'S CERTIFICATION.  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Leach Drilling Contractor  
 Address 306 599 Silver Springs Rd Contractor  
NV 89429  
 Nevada contractor's license number 0031841  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1878  
 Signed Tom Leach  
 By driller performing actual drilling on site or contractor  
 Date 3-1-05

Date started 2-14-05, 20\_\_\_\_\_  
 Date completed 3-1-05, 20\_\_\_\_\_  
 7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30+</u>	<u>280</u>	<u>4 Hrs</u>

RECEIVED  
 OSNARI AM 11:21  
 STATE ENGINEERS OFFICE