WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95693
Permit No.
Basin 091

NOTICE OF INTENT NO. 49555

1. OWNER Somersett LLC
MAILING ADDRESS P.O. Box 34360
Reno, NV 89533

ADDRESS AT WELL LOCATION NE corner of Mesa Trail and Crescent Pointe in the Somersett Subdivision

2. LOCATION SW 1/4 NE 1/4 Sec. 10 T 19N N/S R 18E E Washoe County
PERMIT NO. 66535 (Issued by Water Resources) 234-021-12 (Parcel No.) Somersett (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Measured static water level at 72.13' and depth of well at 918'. Since well was originally 920' we did not run in bailer. Installed 903' of 2" tremme line. Started pumping neat cement at 11:00 am and finished pumping at 4:00 pm. Well required 29 yards of neat cement. Actual well volume was 18.5 yards. Checked well the following morning and cement had setteld to 18" below surface.				

RECEIVED
05 MAR 10 AM 11:28
STATE ENGINEERS OFFICE

Date started 2/28/2005, 19__
Date completed 3/4/2005, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 920 Feet Depth Cased 920 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10"		.250"	+2	920'

Perforations:
Type perforation slotted pipe
Size perforation 3/32 x 3"
From see log feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 920'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 72.13' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Carson Pump (Contractor)
Address P.O. Box 20159 (Contractor)
Carson City, NV. 89721
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed (By driller performing actual drilling on-site or contractor)
Date 3/9/2005

USE ADDITIONAL SHEETS IF NECESSARY