COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95696
Permit No.
Basin 101

NOTICE OF INTENT NO. 54862

1. OWNER Coverston Construction
MAILING ADDRESS P.O. Box 1016
~~Fallon, NV 89407~~ Carson City, NV

ADDRESS AT WELL LOCATION Coverston Construction
4577 Rancheria Dr
Fallon, NV 89406

2. LOCATION sw ¼ sw ¼ Sec 16 T 19 N R 28 E Churchill County

PERMIT NO. | Issued by Water Resources | 008-121-85 Parcel No | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	5	5
Brown Clay		5	35	30
Brown Sand		35	55	20
Gray Clay		55	57	2
Gray Sand		57	59	2
Black Sand		59	70	11
Black Clay		70	76	6
Black Sand		76	90	14
Gray Clay		90	92	2
Gray Sand		92	96	4
Brown Clay		96	110	14
Brown Sand		110	130	20
Black Clay		130	142	12
Black Sand		142	160	18
Gray Sand		160	189	29
Brown Clay		189	192	3
Bown Sand	XX	192	200	8

RECEIVED
05 MAR -4 PM 1:14
STATE ENGINEER'S OFFICE

Date started 11/24, 20 04
Date completed 12/2, 20 04

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	200 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6 pVC	3.82	.258	20	200

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 195 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100 ☐ Neat Cement
Placement Method: ☒ Pumped ☒ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 200 feet

9. WATER LEVEL

Static water level 34 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling Inc (CONTRACTOR)
Address P.O. Box 1265 (CONTRACTOR)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753-T1
Signed [signature] By driller performing actual drilling on site or contractor
Date 2/24/05

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com