COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95698
Permit No.
Basin 101

NOTICE OF INTENT NO. 54856

1. OWNER Hawk Properties
MAILING ADDRESS 2171 W Williams PMB 280
Fallon, NV 8406

ADDRESS AT WELL LOCATION Hawk Properties
4516 Pelican Drive
Fallon, NV 89406

2. LOCATION se ¼ se ¼ Sec 21 T 19 N R 28 E Churchill County

PERMIT NO. (Issued by Water Resources) | 008-283-11 (Parcel No.) | (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	5	5
Brown Clay		5	22	17
Brown Sand		22	37	15
Gray Clay		35	40	5
Black Clay		40	46	6
Black Sand		46	60	14
Gray Clay		60	62	2
Gray Sand		62	67	5
Brown Clay		67	69	2
Brown Sand	XX	69	80	11

RECEIVED 05 MAR -4 PM 1:10 STATE ENGINEER'S OFFICE

Date started 11/15, 20 04
Date completed 11/15, 20 04

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 80 Feet Depth Cased 80 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	80 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6 PVC	3.82	.258	20	80

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 75 feet to 80 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50 ☐ Neat Cement
Placement Method: ☒ Pumped ☒ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 80 feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling Inc (CONTRACTOR)
Address P.O. Box 1265 (CONTRACTOR)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753-T1
Signed [signature] By driller performing actual drilling on site or contractor
Date 02/24/05

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com