

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

office use only
Log No. 95705
Permit No.
Basin 82

1. OWNER **Lennar Reno**
MAILING ADDRESS **6195 Ridgeview Court**
Reno NV 89509

ADDRESS AT WELL LOCATION

NOTICE OF INTENT NO 54851
1441 Geiger Grade
W-1 STM61D

2. Location **NE 1/4 NE 1/4 Sec 28 T 16N R 20E**
PERMIT NO. **PARCEL NO. 140-030-29**

Washoe County

SUBDIVISION NAME

3. WORK PERFORMED			4. PROPOSED USE			5. WELL TYPE		
New Well	Replace	Recondition	Domestic	Irrigation	Test	Cable	Rotary	RVC
Deepen	X Abandon	Other	Municipal/Industrial	Monitor	Stock	Air	Other	Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Perfed from 0 to 60'				0
Perforator would not go lower.				0
Installed termie to 100' & pumped 10 yards of neat cement.				0
We did get returns				0

8. WELL CONSTRUCTION

Depth Drilled	100 feet	Depth Cased	100 feet
HOLE DIAMETER (BIT SIZE)			
	From	To	
inches	0	feet	feet
inches		feet	feet
inches		feet	feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12 3/4			+1 1/2	60
unknow			60	100

Perforations:

Type Perforation	Mills Knife
Size perforation	1/4 x 4"
From 0 feet to 60 feet	
From feet to feet	
From feet to feet	
From feet to feet	
From feet to feet	

Surface Seal X YES No Seal Type:
Depth of Seal 100 feet X Neat Cement
x Pumped Cement Grout
Poured Concrete Grout

Gravel Packed: Yes No
From feet to feet

9. WATER LEVEL

Static water leve	30 feet below land surface
Artesian flow	0 GPM 0 P.S.I.
Water Temperature	cold Degrees F Quality

Date started **11-10 -04**
Date completed **11-10 -04**

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	x Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (hours)	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **McKay Drilling, Inc.**
2290 Pioneer Drive
Reno, NV 89509
NV Contractors No. **14170**
NV Driller's Lic (on site) **2236**

Signed *Steve McKay*
By driller performing actual drilling on site or contractor
Date **11-15 -04**

RECEIVED
05 JAN -6 AM 11:36
STATE ENGINEERS OFFICE