

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



office use only
Log No. **95711**
Permit No.
Basin **105**
NOTICE OF INTENT NO 53629

1. OWNER **Leo Hanly**
MAILING ADDRESS **1310 Hwy 88**
Minden, NV

ADDRESS AT WELL LOCATION **1310 Hwy 88**

2. Location **NW 1/4 NW 1/4 Sec 5 T 12N R 20E Douglas County**
PERMIT NO. **PARCEL NO. 1220-06-001-004** SUBDIVISION NAME

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & gravel.		0	20	20
Rock & gravel.		20	115	95
Sand & gravel.		115	190	75
Clay.		190	200	10
Gravel & rock.		200	218	18

8. WELL CONSTRUCTION
 Depth Drilled **218 feet** Depth Cased **218 feet**
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 inches 0 feet **218** feet
 inches feet feet
 inches feet feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.94	188	+1 1/2	218

Perforations:
 Type Perforation **Factory**
 Size perforation **3/32 x 3"**
 From **158** feet to **218** feet
 From feet to feet
 Surface Seal YES No Seal Type:
 Depth of Seal **100** feet Neat Cement
 Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From **100** feet to **218** feet

9. WATER LEVEL
 Static water level **7** feet below land surface
 Artesian flow **0** GPM **0** P.S.I.
 Water Temperature **cold** Degrees F Quality

Date started **10-27 -04**
 Date completed **11-1 -04**

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	x	Air Lift
G.P.M.	Draw Down (Feet Below Static)			Time (hours)
100	93			1
150	143			2

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **McKay Drilling, Inc.**
2290 Pioneer Drive
Reno, NV 89509
 NV Contractors No. **14170**
 NV Driller's Lic (on site) **786**
 Signed
 By driller performing actual drilling on site or contractor
 Date **11-9 -04**

RECEIVED
 05 JAN -6 AM 11:35
 STATE ENGINEERS OFFICE