

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
 Log No. 95762  
 Permit No. \_\_\_\_\_  
 Basin 089

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 52244

1. OWNER Jerry Hoffman ADDRESS AT WELL LOCATION 3050 Eastlake Blvd.  
 MAILING ADDRESS P.O. Box 3404 Washoe Valley  
Incline Village, NV 89450

2. LOCATION NE 1/4 SE 1/4 Sec. 31 T 17N N S R 20E E Washoe County  
 PERMIT NO. W575A/71544 50-419-08 Parcel No. \_\_\_\_\_  
 Issued by Water Resources Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Coarse sand some fine		0	130	130
Coarse sand	x	130	145	15
Coarse sand pea gravel				
some rock	x	145	166	21
Sandy clay hard		166	180	14
coarse sand	x	180	194	14
Coarse sand some small				
rock		194	203	9
Hard sand		203	220	17
Boulders	x	220	226	6
Granite		226	230	4

Washoe County Well Permit # WL 040333

RECEIVED  
 05 JUN 10 PM 1:24  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 230 Feet Depth Cased 230 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Feet 230 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+2</u>	<u>230</u>

Perforations:  
 Type perforation Machine cut  
 Size perforation 3/32 x 3  
 From 130 feet to 150 feet  
 From 170 feet to 190 feet  
 From 210 feet to 230 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 105 \_\_\_\_\_  
 Neat Cement  
 Placement Method:  Pumped  Poured  Cement Grout  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 105 feet to 230 feet

9. WATER LEVEL  
 Static water level 97 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Bruce MacKay Pump & Well Service, Inc. Contractor  
 Address 1600 Mt. Rose Hwy Contractor  
Reno, NV 89511  
 Nevada contractor's license number issued by the State Contractor's Board 23096  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2205  
 Signed R. Bruce MacKay  
 By driller performing actual drilling on-site or contractor  
 Date 1/5/2005

Date started 12/27/2004 19  
 Date completed 1/5/2005 19

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25+</u>		<u>3</u>