WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95745
Permit No.
Basin 105

NOTICE OF INTENT NO. 54011

1. OWNER Silveira Construction
MAILING ADDRESS 993 Springfield Drive
Gardnerville, NV 89460

ADDRESS AT WELL LOCATION 198 Taylor Creek Road, Gardnerville, NV

2. LOCATION NE 1/4 NE 1/4 Sec. 04 T 12N N/S R 19E E Douglas County
PERMIT NO. (Issued by Water Resources) 1219-04-001-016 (Parcel No.) Taylor Creek (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Coarse sand		0	5	5
Coarse sand & boulders		5	26	21
Coarse sand & small rock		26	80	54
Coarse sand layers small rock		80	160	80
Hard rock boulders coarse sand		160	200	40

RECEIVED 05 JAN 10 PM 1:24 STATE ENGINEER'S OFFICE

Date started 12/14/2004, 19__
Date completed 12/16/2004, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
200		3 hrs.

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	200

Perforations:
Type perforation Machine cut
Size perforation 3/32 X 3
From 140 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 200 feet

9. WATER LEVEL
Static water level 69' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2205
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 12/29/2004

USE ADDITIONAL SHEETS IF NECESSARY