WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 95748
Permit No.
Basin 105

NOTICE OF INTENT NO. 54012

1. OWNER Bray Custom Homes
MAILING ADDRESS P.O. Box 2436
Minden, NV 89423

ADDRESS AT WELL LOCATION 181 Taylor Creek Road,
Gardnerville NV.

2. LOCATION NE 1/4 NE 1/4 Sec. 04 T 12N N/S R 19E E Douglas County
PERMIT NO. (Issued by Water Resources) 1219-04-001-028 (Parcel No.) Taylor Creek (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Coarse sand		0	12	12
Solid rock		12	17	5
Coarse sand & boulders		17	46	29
Solid boulders		46	49	3
Coarse sand some rock		49	85	36
Coarse sand D.G.		85	140	55
Coarse sand some D.G.		140	160	20
Coarse sand D.G., boulders		160	245	85
Boulders rock coarse sand		245	278	33

RECEIVED
05 JAN 10 PM 1:24
STATE ENGINEER'S OFFICE

Date started 12/16/2004, 19__
Date completed 12/21/2004, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		3 hrs.

8. WELL CONSTRUCTION
Depth Drilled 278 Feet Depth Cased 278 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	278	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	278

Perforations:
Type perforation Machine cut
Size perforation 3/32 X 3
From 218 feet to 278 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 100 feet to 278 feet

9. WATER LEVEL
Static water level 130 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2205
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 12/29/2004

USE ADDITIONAL SHEETS IF NECESSARY