

Log No. 95755
 Permit No. _____
 Basin. 002

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 52514

1. OWNER Clark Morris ADDRESS AT WELL LOCATION Denio
 MAILING ADDRESS 1027 South 7th Street
Haberly, OR 97630
 2. LOCATION SE 1/4 NE 1/4 Sec. 5 T. 47 N. R. 30 E Humboldt County
 PERMIT NO. 02-061-45 Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Topsail		0	3	3
Clay		3	15	12
Sand + Gravel		15	30	15
Clay		30	35	5
Sand + Gravel		35	55	20
Clay		55	65	10
Sand + Gravel		65	75	10
Clay Brown		75	81	6
Sand + Gravel		81	84	3
Clay		84	91	7
Sand + Gravel		91	100	9
Clay		100	105	

8. WELL CONSTRUCTION
 Depth Drilled 105 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 105 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>10</u>	<u>1 3/8</u>	<u>0</u>	<u>20</u>
<u>6 3/4</u>	<u>4.06</u>	<u>1 3/16</u>	<u>20</u>	<u>100</u>

Perforations:
 Type perforation Screen
 Size perforation 0.50 slot
 From 90 feet to 100 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 50 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 50 feet to 100 feet

9. WATER LEVEL
 Static water level 47 feet below land surface
 Artesian flow N/A G.P.M. _____ P.S.I. _____
 Water temperature 60.1 °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fred Anderson Drilling, Inc
 Address 10760 Grass Valley Rd
Winnemucca, NV 89445
 Nevada contractor's license number 021467
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 2083
 Division of Water Resources, the on-site driller
 Signed [Signature]
 Date December 30, 2004

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
		<u>4</u>

Date started Dec 20 2004
 Date completed Dec 23 2004

RECEIVED
 05 FEB -3 AM 11:51
 STATE ENGINEERS OFFICE