

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 05759
 Permit No. _____
 Basin 87

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49872

1. OWNER Robert Togliatti ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 16950 South Virginia 201 Rhodes Road
Reno, NV 89511 Reno, NV 89511

2. LOCATION SE 1/4 SW 1/4 Sec 33 T 18 N R 20 E Washoe County

PERMIT NO. N/A 017-301-14
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay and broken rock		0	40	40
River bed sand, gravel, boulders	xx	40	96	56
Dark Brown clay		96	160	64
Blue Clay		160	164	4
Serpentine		164	184	20
Black Volcanic rock	xx	184	197	13
Blue Clay		197	205	8
Multi Colored Volcanic rock	xx	205	245	40

8. WELL CONSTRUCTION
 Depth Drilled 245 Feet Depth Cased 245 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 1/4 Inches 0 Feet 8 Feet
9 7/8 Inches 8 Feet 245 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8"</u>	<u>13</u>	<u>.188"</u>	<u>-1'</u>	<u>8'</u>
<u>6 5/8" PVC</u>	<u>4.95</u>	<u>.390"</u>	<u>8</u>	<u>245</u>

Perforations:
 Type perforation Mill Slot
 Size perforation .030
 From 172 feet to 245 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 105 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 105 feet to 245 feet

9. WATER LEVEL
 Static water level 35 feet below land surface
 Artesian flow none G.P.M. none P.S.I.
 Water temperature cool °F Quality good

Date started 12-22, 20 04
 Date completed 1-10, 20 05

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name MILLER & SONS DRILLING CO.
 (CONTRACTOR)
 Address P.O. Box 8056
 (CONTRACTOR)
Reno, NV 89507
 Nevada contractor's license number issued by the State Contractor's Board 037915
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418
 Signed Bruce Miller
 By driller performing actual drilling on site or contractor
 Date 2-5-05

7. WELL TEST DATE

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>Approx</u>	<u>30</u>	<u>200</u>	<u>4</u>